

SUBMITTAL DATA - INDOOR UNIT VEHW007N432T VRF WALL MOUNTED TYPE EVAPORATOR

Job Name:	Engineer:		
Location:	Architect:		
Schedule No.:	Date:		
System Designation:	For: Reference Approval Review Construction		

FEATURES

- Auto Addressing installation
- Auto Restart
- Auto Swing Louvers
- Built-in Electronic Expansion Valve
- LED Display
- Washable Filter

- Mildew-proof Filter
- Anti-Freezing Protection
- Enameled finish

PRODUCT WARRANTY

All covered components - Five year limited warranty


SPECIFICATIONS		
PERFORMANCE		
Cooling Capacity* (Btu/h)		7,506
Heating Capacity* (Btu/h)		8,530
Airflow (CFM)	High	294
	Medium	247
	Low	206
Sound Pressure Level (dBA)	H/M/L	38/34/30
ELECTRICAL DATA	220-2	40 / 50 / 1

220-240 / 50 / T	
	6
Cooling	0.2
Heating	0.2
	Cooling

DIMENSIONS

Unit Dimensions (in)	Height Width Depth	10 3/4 33 1/8 7
Liquid Pipe Connection (in) Gas Pipe Connection (in) Shipping Weight (lb) Net Weight (lb)		1/4 3/8 27.5 22





- 1. Surface Panel
- 2. Air Filters
- 3. Electronic Box Cover
- 4. Swing Louvers
- 5. Drain Hose

NOTES:

*Cooling and Heating Capacity data is rated at the following conditions:

Cooling: 80 °F DB / 67 °F WB Indoor, 95 °F DB Outdoor


Heating: 70 °F DB Indoor, 47 °F DB


NOTE – Due to Lennox' ongoing commitment to quality, Specifications, Ratings and Dimensions subject to change without notice and without incurring liability. Improper installation, adjustment, alteration, service or maintenance can cause property damage or personal injury. Installation and service must be performed by a qualified installer and servicing agency. ©2017 Lennox Industries Inc.




SUBMITTAL DATA - INDOOR UNIT VEHW007N432T VRF WALL MOUNTED TYPE EVAPORATOR

DIMENSIONAL DRAWINGS







NOTE – Due to Lennox' ongoing commitment to quality, Specifications, Ratings and Dimensions subject to change without notice and without incurring liability. Improper installation, adjustment, alteration, service or maintenance can cause property damage or personal injury. Installation and service must be performed by a qualified installer and servicing agency. ©2017 Lennox Industries Inc.